

Exhibit EE

North Valley

Outage Report

Report Printed Wed Jul 14 14:51:01 PDT 2021		
Date From	Date To	Outage Type Both
OutNum 21-0089207	Equipment Type	Equip Condition
Equipment Involved	Equipment Cause	Equipment Supplemental
Outage Level	Outage Interval	Fault Type
Action Required Both	Active Both	Circuit
EquipID	Fire Mitigation No	District

[Export To Excel](#)

Unplanned Outages

Paradise

Circuit	102211101, BUCKS CREEK-1101	Event Log	21-0089207
Type	Unplanned	Weather	Clear;32-90F
Customers	CESO 4 CEMO 0 ADJ CESO 3 Initial 2	Customer Minutes	Sus 460 Mom 0 Adj Sus 460 CAIDI 153
Active	YES	Fault Type	Line to Line
Interval	Sustained	Action Required	No
EquipID	17733	Construction Type	OH
Equipment Type	Fuse	OIS Outage#	1403761
Equipment Condition	Conductor, Overhead, Normal	Targets	
Crew Notified Time		Supervisor Notified	
Equipment Address	CRESTA DAM TAP W/O SW 17183	Fire Mitigation	No
Fault Location	1ST SPAN LD SIDE OF FUCO 17733		
Previous Switching Details	VEG FIRE IN AREA		
Action Description		Wire Down Energized	No
Cause	Vegetation, Tree - fell into line	No Access Reason	
Multi Damage Location	No	# of Operations	
Counter Read		Created By	
Outage Level	Distribution Circuit	Last Updated By	
FNL	07/13/21 16:40	Reviewed By	Not Required
End Date		Reviewed By Date	
Date	Description	Customers Restored	
07/13/21 16:40	FUSE 17733 OPEN- [REDACTED] FOUND FUCO 17733 #1 AND #2 BLOWN OPENED REMAINING 0 AND TAGGED MOL -TREE IN THE LINE - GRASS FIRE- CALLED CPUC- D.O. NOTIFIED OF FUSES BLOWN AT 2250; [REDACTED] HAD ALSO REPORTED THAT THERE WERE MULTIPLE CONSTRUCTION CREWS IN THE AREA WORKING ON THE BRIDGE AND TUNNEL ALL NEAR THE TROUBLE AREA, TOOK AN EXTRA 2 HOURS TO GET AROUND THEM TO GET TO THE LOCATION		
07/13/21 20:30	SWITCH 941 OPEN & T/MOL, PER TMAN [REDACTED] & [REDACTED]; PER CAL FIRE REQUEST TO OPEN SWITCH FOR SAFETY DUE TO A FIRE IN THE AREA	-1	